

## ERRATA

### American National Standard Mobile Radioactive Waste Processing Systems, ANSI/ANS-40.37-1993

**Table 2, Equipment Codes**, on page 25, contains a typographical error. Footnote d of the table refers the user to Appendix A, item #10.

The correct item number is **#8**. The corrected table appears below.

Table 2

Equipment Codes

Equipment	Design and Fabrication	Materials <sup>a</sup>	Welder Qualification and Procedures	Inspection and Testing
Pressure Vessels	ASME B&PVC, Section VIII, Division 1	ASME B&PVC, Section II	ASME B&PVC, Section IX	ASME B&PVC, Section VIII, Division 1
Atmospheric Tanks	ASME B&PVC, <sup>b</sup> Section III, Class 3; or API 650; or AWWA D-100 <sup>c</sup>	ASME B&PVC, <sup>c</sup> Section II	ASME B&PVC, Section IX	ASME B&PVC, <sup>b</sup> Section III, Class 3; or API 650; or AWWA D-100 <sup>c</sup>
0-15 PSIG Tanks	ASME B&PVC, <sup>b</sup> Section III, Class 3; or API 620 <sup>c</sup>	ASME B&PVC, <sup>c</sup> Section II	ASME B&PVC, Section IX	ASME B&PVC, <sup>b</sup> Section III, Class 3; or API 620 <sup>c</sup>
Heat Exchangers	ASME B&PVC, Section VIII, Division 1; and TEMA <sup>d</sup>	ASME B&PVC, Section II	ASME B&PVC, Section IX	ASME B&PVC, Section VIII, Division 1
Piping and Valves	ANSI B31.1	ASTM; and ASME B&PVC, Section II	ASME B&PVC, Section IX	ANSI B31.1
Pumps	Manufacturers' Standards <sup>e</sup>	ASME B&PVC, Section II; or Manufacturers' Standards	ASME B&PVC, Section IX (as required)	ASME B&PVC, <sup>b</sup> Section III, Class 3; or Hydraulic Institute

<sup>a</sup> Manufacturers' material certificate of compliance with material specifications may be provided in lieu of certified material test reports. Cast, wrought, or malleable iron shall not be used.

<sup>b</sup> ASME Code stamp, material traceability, and the quality assurance criteria of Appendix B to 10 CFR Part 50 are not required. Therefore, these components are not classified as ASME Code Class 3.

<sup>c</sup> Fiberglass-reinforced plastic tanks may be used in accordance with appropriate articles of Section X of the ASME Boiler and Pressure Vessel Code for applications at ambient temperature.

<sup>d</sup> See Appendix A, item # 8.

<sup>e</sup> Manufacturers' standard for the intended service. Hydrotesting should be 1.5 times the design pressure.